



# Certificate of Compliance

Certificate Number: LR112529-4

Revision:

Date Issued: August 28, 1998

Issued to: **Shihlin Electric & Engineering Corp.**  
**No. 234, Chun-Lun, Hsin-Fung, Hsin-Chu**  
**Taiwan**  
**Attention: Mr. Pai**

*The products listed below are eligible to bear the CSA Mark*

<sup>1</sup>NOTE: The "NRTL/C" indicator also appears adjacent to the CSA Mark.

Issued by: V. Salluce  
Toronto, ON Canada

Signature: 

## PRODUCTS

CLASS 3211 04 - INDUSTRIAL CONTROL EQUIPMENT - Motor Controllers - Magnetic  
CLASS 3211 84 - INDUSTRIAL CONTROL EQUIPMENT - Motor Controllers - Magnetic - CERTIFIED TO  
U.S. STANDARDS

Magnetic Motor Controller (Contactor), Model S-P11, open-type.

Rated:	Main Contacts -	Volts	Horsepower	
			1ph	3Ph
		110 -120	0.5	--
		220-240	2.0	3.0
		440-480	--	7.5
		550-600	--	10

Continuous current - 24A, 600Vac max.; short circuit - 5000A, 240Vac, single phase; 5000A, 600Vac, three phase;  
Auxiliary contact - A600; coil - 12 to 550Vac, 60hz; 12 to 500Vac, 50hz.

## APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No.	14-95	-Industrial Control Equipment
UL Std No.(16th Ed.)	508	-Industrial Control Equipment

<sup>1</sup>The "NRTL/C" indicator adjacent to the CSA Mark signifies that the product has been evaluated to the applicable ANSI/UL and CSA Standards, for use in the U.S. and Canada. NRTL, i.e. Nationally Recognized Testing Laboratory, is a designation granted by the U.S. Occupational Safety and Health Administration (OSHA) to laboratories which have been recognized to perform certification to U.S. Standards.