

表 1. 限用物質含有情況超出百分比含量基準值之標示

設備名稱：無熔線斷路器(MCCB)，型號（型式）： NF800-CN Equipment name Type designation (Type)						
單元 Unit	限用物質及其化學符號 Restricted substances and its chemical symbols					
	鉛 Lead (Pb)	汞 Mercury (Hg)	鎘 Cadmium (Cd)	六價鉻 Hexavalent chromium (Cr ⁺⁶)	多溴聯苯 Polybrominated biphenyls (PBB)	多溴二苯醚 Polybrominated diphenyl ethers (PBDE)
金屬件(鐵件/銅件/螺絲)	○	○	○	○	○	○
塑膠件(外殼/把手)	○	○	○	○	○	○
電氣接點	○	○	○	○	○	○
絕緣材料	○	○	○	○	○	○
銅燃線	○	○	○	○	○	○

備考1. “超出0.1 wt %” 及 “超出0.01 wt %” 係指限用物質之百分比含量超出百分比含量基準值。
Note 1 : “Exceeding 0.1 wt %” and “exceeding 0.01 wt %” indicate that the percentage content of the restricted substance exceeds the reference percentage value of presence condition.

備考2. “○” 係指該項限用物質之百分比含量未超出百分比含量基準值。
Note 2 : “○” indicates that the percentage content of the restricted substance does not exceed the percentage of reference value of presence.

備考3. “—” 係指該項限用物質為排除項目。
Note 3 : The “—” indicates that the restricted substance corresponds to the exemption.

適用機種的型式與系列型式

型式	NF800-CN 3P/4P 60Hz 690V 800AF(700A/800A) Icu/Ics:50/25kA(220V), 35/18kA(380V), 30/15kA(440V)
----	--